

STAFF MINUTE SHEET

From : Officer-in-Charge, SHO 227/15/SHO
प्रभागीय अधिकारी, स्था स्वा सं INS Valsura/ भा नौ पो वलसुरा
Jamnagar/ जामनगर

To : EXO/कर्तव्य कार्यपाल अधिकारि 29 Jan 24/ जनवरी २४

Copy to : CTS, GE (N), AGE (E&M), KV School
क.त.से, जि ई (नौ), ए.जि.ई (ई & एम),
केंद्रीय विद्यालय

**BACTERIOLOGICAL EXAMINATION REPORT OF DRINKING WATER
FOR THE MONTH OF JAN 24**

Bacteriological Examination of drinking water for the month of Jan 24 from various locations were carried out at XL laboratory Jamnagar on 23 Jan 24. The report of the same is enclosed herewith.

(ललित कुमार शर्मा / Lalit Kumar Sharma)
सर्जन कमांडर / Surgeon commander
प्रभागीय अधिकारी/Officer-in-Charge


02/3/24

ran Kumare 1



To,
The Officer-in-charge
INS VALSURA
Indian Coast Guard Station Valsura
JAMNAGAR-361150

Next to Dr. Ruparelly Hospital,
 Near Gurudhwara, J.G. Marg, Jamnagar-361003.
 Phone No-0288-2661718. For Home visit -9054844253

Date :23-01-2024

MICROBIOLOGICAL ANALYSIS OF WATER

NO.	WATER SAMPLES FROM	Coliform Count	CATEGORY
		MPN/ml	
1	Pump House No 1 (RO PLANT)	2	<u>B</u>
2	Ward Room (RO PLANT)	0	<u>A</u>
3	Trishul Galley	1	<u>B</u>
4	Sailors Institute	0	<u>A</u>
5	Central Galley	2	<u>B</u>
6	60 Civilian Quarter	0	<u>A</u>
7	88 Leading (RO Plant)	0	<u>A</u>
8	Kendriya Vidhyalaya	1	<u>B</u>
9	SMA Market (RO Plant)	0	<u>A</u>

Comments :


Water samples from.

- 1 Pump House No.1 (RO PLANT) **Acceptable.**
- 2 Ward Room (RO PLANT) **Excellent.**
- 3 DSC Galley **Acceptable.**
- 4 Sailors Institute **Excellent.**
- 5 Central Galley **Acceptable.**
- 6 Kunthal Galley **Excellent.**
- 7 88 Leading (RO Plant) **Excellent.**
- 8 Kendriya Vidhyalaya **Acceptable.**
- 9 SMA Market (RO Plant) **Excellent.**

Mean Count / 100 ml	Category	Comments
0	<u>A</u>	Excellent
1 - 10	<u>B</u>	Acceptable But make regular sanitary checks.
10 - 50	<u>C</u>	Unacceptable Poor maintenance Disinfect source.
More than 50	<u>D</u>	Grossly polluted Look for alternative source or disinfect source.



(Jait Singh Sharma)
 Surgeon Commander
 Officer-in-Charge



Dr. Tejal P. Kotecha (M.D)
 (M) 99879578789